



INSTRUCTION MANUAL - English

Ceramic electrode-holder - series 395

Code: 395-010-00

Thank you for purchasing ceramic electrode-holder series 395.

Before using the device, please read carefully this manual, and keep it in a safe place, for future use.

1 - Description

The electrode-holder series 395 allows ON/OFF monitoring of level for conductive liquid.

They are particularly useful in boilers and steam generators.

The level switches to be used together with the electrode-holder series 395, are all of our products of the series 200, 203, 201 or 204 (delayed).

The electrode is in stainless steel; the isolation is in ceramics (Al_2O_3).

2 - Technical characteristics

- thread: 2" gas
- protection grade: IP55
- electrode diameter: 6 mm
- maximum temperature at the electrode: 250 °C
- maximum pressure: 25 bar
- weight: 1300 g

3 - Mechanical dimension




Fig.1



4 - Installation and use

For a correct installation follows the 3 following phases:

- determination of the electrode length
- fixing the electrode-holder on the boiler
- electric connection

4.1 The boiler has to be depressurize and vented to atmosphere, before the installation of the electrode-holder.

Every operation on the electrode-holder must be performed only by qualified staff and always with boiler depressurize and cold.

4.2 Determination of the length of the electrode

First of all, it is necessary decide the electrode length, according to the desired water level, keeping in mind thread and junction length.

The switching point is at the lower end of the electrode.

Once the length is decided, proceeds to the electrode cut.

The electrode must be mechanically assembled to the electrode-holder as in the following drawing:




Fig.2

First, lock the electrode to the cylinder; then grip the cylinder with pliers, and tighten the electrode with others pliers. Then lock the nut to the cylinder: grip the cylinder with pliers, then tighten the nut with a wrench.

Don't rotate absolutely the threaded electrode and the electrode in the electrode-holder.

4.3 Installing of the electrode-holder

The electrode-holder series **395** must be vertically assembled on the boiler, through a threaded 2" hole.

The electrodes doesn't have to touch the wall of the boiler or the protective tube in which it is contained.

The electrode-holder must be handled with care; it doesn't have to suffer drop or impact.

A drop could break the internal ceramics, without notice by visual examination; in case of drop, do not use the electrode-holder, but return it to MMT for a check/test.



The electrode-holder has to be screwed only acting on the hexagon SW24 with a special wrench; put 5 turns of teflon ribbon on the thread of the probe, to make the necessary seal on the boiler.

Don't absolutely act on the ring nut that is up the hexagon SW24, to avoid ceramics break.

5 Wiring connection

The higher end of the electrode-holder, is a electrode of stainless steel, 4 MA threaded with nut in stainless steel.

For the electric connection refer to the following drawing:




Fig.4

It is possible to use either a male faston connector or a eyelet terminal with 4mm hole.

Lock them with a 4 MA nut.

Insert the terminal with the electric cable coaxially with the electrode, placing it on the first nut; then screw a second 4 MA nut.

Lock the terminal among the 2 nuts: holding the lower, act with a wrench on the higher.

Don't absolutely rotate the threaded electrode.

The connection cable is according to the level switch used.

Using our **200, 203, 201 or 204** series level switches, use cables, not necessarily screened, with section larger than 1 mmq.

The cables must not be channel together with power cables.

The cable length depends on the type of level switch used.

For switch with a.c. power supply (for standard and low sensibility), and for those with d.c. power supply (for all sensibility), the cables can be long up to 200 m. For the switch with a.c. power supply (for high sensibility), the cables have to be the shortest possible; in the range 1÷20 μ S maximum length is 40 m; in the range 0.3÷2 μ S, maximum length is 10 ms.

6 – Warning

The boiler has to be depressurize and vented to atmosphere before the installation of the electrode-holder.

Every operation on the electrode-holder must have performed only by qualified staff and always with boiler depressurize and cold.

The electrodes doesn't have to touch the wall of the boiler or the protective tube in which it is contained.

Don't turn the electrodes in the probe.